

INORGANIC CONTAMINANT	MCL	MCLG	LEVEL DETECTED	SAMPLE DATE	SOURCE
Fluoride (ppm)	4	4	1.4	5/01	Water additive to promote dental health
Lead (ppb)	15	0	< 5	10/02	Alloyed Fixtures
Copper (ppm)	1.3	AL = 1.3	0.03	10/02	Corrosion of household plumbing systems
RADIO NUCLIDES					
Gross Alpha emitters (pCi/l)	15	0	1	1/99	Erosion of natural deposits
Beta emitters (mrem/yr)	4	0	< 2	1/99	
Combined Radium (pCi/l)	5	0	< 2	1/99	
UNREGULATED CONTAMINANTS					
Sodium (ppm)	Not regulate d		0.72	12/98	EPA requires monitoring while we consider setting limits.
Radon 222 (pCi/l)	"	"	30	1/99	" "
Chloroform (ppb)	"	"	0.8	4/98	" "
Bromodichloromethane (ppb)	"	"	0.7	4/98	" "
Dibromochloromethane (ppb)	"	"	0.7	4/98	" "

We want our customers and citizens to be informed about their water utility. If you have any questions about this report or concerning your water utility, please contact the Superintendent, Thomas L. Crabtree, or the Assistant Superintendent, Jim Bolitho, at the Water Plant (410-224-2140) or the Director of Public Works (410-263-7949).